

SERTIFIKAT O KONTROLISANJU 281112	
Klijent:	„EURO-MONT-ING“ d.o.o., Savska 17, Beograd
Obim i vrsta kontrolisanja:	Kontrolisanje ispunjenosti uslova izvođača radova za montažu predizolovanog sistema projektne klase „C“, saglasno zahtevima standarda EN 13941:2009+A1
Predmet kontrolisanja:	Kontrolisanje definisano radnim nalogom 281112
Izvođač:	„EURO-MONT-ING“ d.o.o., Savska 17, Beograd
Mesto i datum kontrolisanja:	Beograd, 28.11.2011. do 28.12.2012.godine

Ovim potvrđujemo da smo na osnovu usvojene ponude br. 073/12rev INDUSTRY 2 izvršili:

- pregled dokumentacije za montažu predmetnog predizolovanog sistema.
- kontrolu usaglašenosti dokumentacije za montažu predizolovanog sistema sa zahtevima standarda EN 13941

Nakon realizacije predmetnog kontrolisanja, a na osnovu izveštaja 4030/12 utvrđeno je:

- Specifikacija kontrole kvaliteta usaglašena je sa t.4.5.4 standarda EN 13941
- preispitivanje projektne dokumentacije sa proverom izbora projektne klase usaglašeno je sa t.4.4 i 4.5 standarda EN 13941
- Dokumentacija vezana za montažu predizolovanog sistema usaglašena je sa t.7 standarda EN 13941
- prijemno kontrolisanje elemenata predizolovanog sistema, ostalih materijala i komponenata koji se koriste pri montaži predizolovanog sistema usaglašeno je sa t.5 standarda EN 13941.
- Aktivnosti transporta i istovara, koja se realizuju putem podugovaranja, usaglašene su sa t.7.2 standarda EN 13941
- Zavarivački pogon usaglašen je sa t.7.5.2 i t.7.5.3 standarda EN 13941.
- podugovorena ispitivanja metodama bez razaranja usaglašena su sa zahtevima t.7.5.2.5 standarda EN 13941.
- Izvođač raspolaže osobljem za koordinaciju zavarivanja, saglasno t.7.5.2.4 standarda EN 13941.
- Zavarivački kadar usaglašen je sa t.7.5.2.3 standarda EN 13941.
- Ispitivanje pritiskom i usaglašeno je sa t.7.6 standarda EN 13941.
- postupak montaže termoskupljajućih spojnica usaglašen je sa zahtevima t.7.7 standarda EN 13941.
- provera sistema za detekciju usaglašena je sa t.7.10.3 standarda EN 13941
- Završna dokumentacija usaglašena je sa zahtevima t.7.1, t.7.5.8, t.7.7 i t.7.10.3 standarda EN 13941
- Potrebno vršiti periodične nadzorne posete, minimalno jednom godišnje

Zaključak:

Nakon realizovanog predmetnog kontrolisanja utvrđeno je da firma „EURO-MONT-ING“ d.o.o., ispunjava zahteve za izvođača radova na montaži predizolovanog sistema daljinskog grejanja za projektnu klasu „C“, saglasno standardu EN 13941:2009 + A1.



This report corresponds to findings at time and place of inspection only.

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.